

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
Hospital	LOWER GROUND	Minor OT-Oncology	HB LG051	2	2	2	0	1	1	1	0
Hospital	LOWER GROUND	Chemo therapy treatment room	HB LG083	1	1	1	0	0	0	0	1
Hospital	LOWER GROUND	LINAC Bunker-1		1	1	1	0	0	0	0	1
Hospital	LOWER GROUND	LINAC Bunker-2		1	1	1	0	0	0	0	1
Hospital	LOWER GROUND	CT -Scan	HB LG125	1	1	0	0	0	0	0	0
Hospital	LOWER GROUND	ETO sterilizer		0	0	1	0	0	0	0	0
HOSPITAL	UPPER GROUND	RECOVERY ROOM - 3 BED	HB UG010	6	6	3	0	0	0	0	3
HOSPITAL	UPPER GROUND	MINOR OT	HB UG027	2	2	2	0	1	1	1	0
HOSPITAL	UPPER GROUND	MINOR OT	HB UG072	2	2	2	0	1	1	1	0
HOSPITAL	UPPER GROUND	POST ANGIO ROOM - 6 BED	HB UG107	12	12	6	0	0	0	0	6
HOSPITAL	UPPER GROUND	HOLDING AREA (CATHLAB) - 4 BED	HB UG115	2	2	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	CATHLAB	HB UG116	2	2	2	0	0	0	0	1
HOSPITAL	UPPER GROUND	CATHLAB	HB UG118	2	2	2	0	0	0	0	1
HOSPITAL	UPPER GROUND	OT (PMR)	HB UG145	2	2	2	0	1	1	1	0
HOSPITAL	UPPER GROUND	RECOVERY ROOM (PMR OT) - 4 BED	HB UG153	8	8	4	0	0	0	0	4
HOSPITAL	UPPER GROUND	MRI ROOM	HB UG329	1	1	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	CT SCAN	HB UG333	1	1	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	CT SCAN	HB UG339	1	1	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	TRIAGE (EMERGENCY) - 10 BED	HB UG424	10	10	0	0	0	0	0	0

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	UPPER GROUND	ISOLATION ROOM	HB UG439	2	2	1	0	0	0	0	1
HOSPITAL	UPPER GROUND	ISOLATION ROOM	HB UG440	2	2	1	0	0	0	0	1
HOSPITAL	UPPER GROUND	RECOVERY (OT) - 6 BED	HB UG468	12	12	6	0	0	0	0	6
HOSPITAL	UPPER GROUND	TRIAGE (TRAUMA) - 10 BED	HB UG480	10	10	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	CT SCAN	HB UG493	1	1	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	MRI ROOM	HB UG499	1	1	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	WARD - 4 BED	HB UG512	2	2	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	RESUSITATION ROOM-4 BED	HB UG514	8	8	4	0	0	0	0	4
HOSPITAL	UPPER GROUND	WARD - 4 BED	HB UG515	2	2	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	WARD - 4 BED	HB UG516	2	2	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	OBSERVATION - 4 BED	HB UG517	2	2	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	WARD - 4 BED	HB UG518	2	2	0	0	0	0	0	0
HOSPITAL	UPPER GROUND	WARD - 4 BED	HB UG519	2	2	0	0	0	0	0	0
HOSPITAL	FIRST	MINOR OT	HB 1002 (C)	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	MINOR OT	HB 1004	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	PROCEDURE ROOM	HB1011	1	1	0	0	0	0	0	0
HOSPITAL	FIRST	MINOR OT	HB1012 ,HB10	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	MINOR OT	HB1027	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	MINOR OT	HB1037,HB10 38	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	MINOR OT	HB 1052	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	HDU 4 BED	HB 1061	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ISOLATION ROOM	HB 1063	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1066	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1072	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1075	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1095(A)	2	2	1	0	0	0	0	1

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	FIRST	ISOLATION ROOM	HB 1095(B)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1095(C)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1095(D)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	HDU 4 BED	HB 1095(E)	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	WARD(6 BED)	HB 1095(F)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1095(G)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1095(H)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1095(I)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1095(J)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1110-11	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	HDU 4 BED	HB 1113,HB 1114	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ISOLATION ROOM	HB 1115(A)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1115(B)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ECLAMPSIA LABOUR ROOM	HB 1127(B)	1	1	0	0	0	0	0	0
HOSPITAL	FIRST	POSTPARTUM	HB 1128	2	2	0	0	0	0	0	0
HOSPITAL	FIRST	DELIVERY ROOM	HB 1129	2	2	0	0	0	0	0	0
HOSPITAL	FIRST	DELIVERY ROOM	HB 1131	2	2	0	0	0	0	0	0
HOSPITAL	FIRST	LABOUR WARD(6 BED)	HB 1134	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	RECOVERY ROOM 3 BED	HB 1153	6	6	3	0	0	0	0	3
HOSPITAL	FIRST	NICU SICK 3 BED	HB 1156(A)	6	6	3	0	0	0	0	3
HOSPITAL	FIRST	NICU PRETERM 5 BED	HB 1156(B)	10	10	5	0	0	0	0	5
HOSPITAL	FIRST	WARD (STEPDOWN ICU)6 BED	HB 1165(A)	12	12	6	0	0	0	0	6
HOSPITAL	FIRST	HDU 4 BED	HB 1165(B)	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	WARD (STEPDOWN ICU)6 BED	HB 1165(C)	6	6	3	0	0	0	0	3
HOSPITAL	FIRST	NURSERY 8 BED	HB 1172-73	6	6	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1174(A)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1174(B)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1175	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1177(A)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1204(A)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1205	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1208(A)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1208(B)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1208(C)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	HDU 4 BED	HB 1208(D)	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	WARD(6 BED)	HB 1208(E)	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1237,HB 1238	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 4 BED	HB 1239	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ISOLATION ROOM	HB 1240	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 4 BED	HB 1242	8	8	4	0	0	0	0	4

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	FIRST	ISOLATION ROOM	HB 1243	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1246	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 4 BED	HB 1247	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ICU 4 BED	HB 1253,HB 1254	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	SPECIAL PROCEDURE ROOM	HB 1261, HB 1262	1	1	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1283	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1284	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1285,HB 1286	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	HDU 4 BED	HB 1288	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	WARD(6 BED)	HB 1290	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1291	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1302	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1305	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ICU 6 BEDED	HB 1327,370,371	12	12	6	0	0	0	0	6
HOSPITAL	FIRST	ISOLATION ROOM	HB 1369,352	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1368,351	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 6 BEDED	HB 1349,350	12	12	6	0	0	0	0	6
HOSPITAL	FIRST	ISOLATION ROOM	HB 1346,365,366	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 6 BEDED	HB 1367,348,349	12	12	6	0	0	0	0	6
HOSPITAL	FIRST	ISOLATION ROOM	HB 1359	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 6 BEDED	HB 1361,360,361	12	12	6	0	0	0	0	6
HOSPITAL	FIRST	ISOLATION ROOM	HB 1343	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ICU 6 BEDED	HB 1376	12	12	6	0	0	0	0	6
HOSPITAL	FIRST	HDU 4 BED	HB 1387	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ISOLATION ROOM	HB 1389	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1390	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1395	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1399	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	MINOR OT	HB 1411(B)	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1418	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1419-HB 1420	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	HDU 4 BED	HB 1422-HB 1423	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	WARD(6 BED)	HB 1424	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1426,HB 1427	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1431	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1432	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	WARD(6 BED)	HB 1439	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1440	4	4	0	0	0	0	0	0

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	FIRST	WARD(6 BED)	HB 1452	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	WARD(6 BED)	HB 1456	4	4	0	0	0	0	0	0
HOSPITAL	FIRST	HDU 4 BED	HB 1465	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ISOLATION ROOM	HB 1468(A)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1468(B)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	MINOR OT	HB 1473(A)	2	2	2	0	1	1	1	0
HOSPITAL	FIRST	ISOLATION ROOM	HB 1474(B)	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	4 BED ICU	HB 1491,493,4	8	8	4	0	0	0	0	4
HOSPITAL	FIRST	ISOLATION ROOM	HB 1495	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	ISOLATION ROOM	HB 1496	2	2	1	0	0	0	0	1
HOSPITAL	FIRST	4 BED ICU	HB 1498,499,5	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2006	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2008	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2011	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2014	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2019	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2021	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	CCU 4 BED	HB 2023	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	PROCEDURE ROOM	HB 2037	1	1	1	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2039	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2040	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2041	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	HDU 4 BED	HB2044	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2045	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ICU 4 BED	HB2077	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2079	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2082	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ICU 4 BED	HB2083	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2097	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2098	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	GI INTERVENTION	HB2100	1	1	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	PROCEDURE ROOM	HB2101	1	1	1	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2099	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2104	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	HDU 4 BED	HB2105	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2108	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2109	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ERCP ROOM	HB2130	1	1	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2141 A	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2141 B	2	2	1	0	0	0	0	1

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2143	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2144	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	HDU 4 BED	HB2147	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2150	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2150 A	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2166	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2167	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2168	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2169	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2172	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2175	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2191	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB2193	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2198	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB2199	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	HDU 4 BED	HB2204	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2209 A	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2209 B	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2210	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2212	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	HDU 4 BED	HB 2214	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2217	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2219	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2258, HB 2259	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2260	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	HDU 4 BED	HB 2263	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2265	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2266	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ENDOSCOPY ROOM	HB 2292	1	1	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2299	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2300	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2301	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2302	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	HDU 4 BED	HB 2303,HB 2304,2T55	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2305	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2306	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2307	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2308	2	2	1	0	0	0	0	1

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2309	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ICU 4 BED	HB 2326	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2328	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2329	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ICU 4 BED	HB 2331	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	RECOVERY ROOM 12BED	HB 2427	12	12	6	0	0	0	0	6
HOSPITAL	2ND FLOOR	HOLDING ROOM 12 BED	HB 2432	12	12	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2452	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	HDU 4 BED	HB 2453	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	WARD(6 BED)	HB 2454	4	4	0	0	0	0	0	0
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2464	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2465	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2471	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2473	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2474	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2476	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2486	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2488	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2489	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2491	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2500	8	8	4	0	0	0	0	4
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2502	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	ISOLATION ROOM	HB 2503	2	2	1	0	0	0	0	1
HOSPITAL	2ND FLOOR	4 BED ICU	HB 2505	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	PRIVATE ROOM	HB 3003	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3004	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3005	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3006	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3007	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3008	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3009	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3010	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3011	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3014	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3015	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3016	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3017	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3018	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3019	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3020	1	1	0	0	0	0	0	0

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	THIRD	PRIVATE ROOM	HB 3021	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3026 B	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3027 B	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3028 B	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3029 B	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PROCEDURE ROOM	HB 3042	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3044	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3046	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3050	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3051	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	HDU 4 BED	HB 3052	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ICU 4 BED	HB 3081-82	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3084	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3086	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3088-89	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	PROCEDURE ROOM	HB 3097	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PROCEDURE ROOM	HB 3098	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3109	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3110	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	WARD(6 BED)	HB 3111	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3112	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3113	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3114	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3115	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3117	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3118	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	WARD 10 BED	HB 3127	6	6	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3138	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3138 B	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	HDU 4 BED	HB 3139	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	WARD(6 BED)	HB 3141	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3147	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3150	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3151	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3162	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3165	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3166	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3168	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3169	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	WARD(6 BED)	HB 3171	4	4	0	0	0	0	0	0

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	THIRD	WARD(6 BED)	HB 3183	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3185	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3189	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3190	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	HDU 4 BED	HB 3198	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3206	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3206 B	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	WARD(6 BED)	HB 3207	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3210	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3223	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3224	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3259	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3261	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ICU 4 BED	HB 3263	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3265	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	DIALYSIS UNIT 7 BED	HB 3283	14	14	7	0	0	0	0	7
HOSPITAL	THIRD	ISOLATION ROOM	HB 3285	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3290	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3291	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	WARD(6 BED)	HB 3292	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3293	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3294	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3297	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3298	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3299	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3300	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	PROCEDURE ROOM	HB 3304	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PERITONIAL DIALYSIS ROOM 6 BED	HB 3305	12	12	6	0	0	0	0	6
HOSPITAL	THIRD	HDU 4 BED	HB 3306	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ICU 4 BED	HB 3328	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3330	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3331	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3333	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	RECOVERY WARD 10 BED	HB 3431-32	10	10	5	0	0	0	0	5
HOSPITAL	THIRD	HOLDING ROOM 10 BED	HB 3434	10	10	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3442 A	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3442 B	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3442 C	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3442 D	1	1	0	0	0	0	0	0

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	THIRD	PRIVATE ROOM	HB 3448 A	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3448 B	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3448 C	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3448 D	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3451	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3452	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3453	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3454	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3455	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3456	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3457	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3458	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3459	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3460	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3463	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3464	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3465	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3466	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3467	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3468	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3469	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3470	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3471	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PRIVATE ROOM	HB 3472	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	PROCEDURE ROOM	HB 3476	1	1	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3480	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	WARD(6 BED)	HB 3488	4	4	0	0	0	0	0	0
HOSPITAL	THIRD	ISOLATION ROOM	HB 3491	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3492	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3497	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3499	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3500	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3502	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ICU 4 BED	HB 3512	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3514	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3515	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3517	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3530	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3532	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ICU 4 BED	HB 3533	8	8	4	0	0	0	0	4

GAS OUTLETS FOR AIIMS BHOPAL											
BLOCK	FLOOR	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	ICU BEDHEAD PANEL
				OXYGEN	VACUUM	AIR 4 BAR	AIR 7 BAR	NITROUS OXIDE	AGSS		
HOSPITAL	THIRD	ISOLATION ROOM	HB 3534	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3546	8	8	4	0	0	0	0	4
HOSPITAL	THIRD	ISOLATION ROOM	HB 3548	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ISOLATION ROOM	HB 3549	2	2	1	0	0	0	0	1
HOSPITAL	THIRD	ICU 4 BED	HB 3551	8	8	4	0	0	0	0	4
TOTAL				1351	1351	445	0	12	12	12	416