

30TR
CHILLER

AHU ROOM

SUPPLY


RETURN

TERRACE FLOOR

water tank

KEYPLAN

- ① RETURN AIR OUTDOOR PLENUM
- ② SUPPLY AIR MAIN DUCT.
- ③ 13000 CFM 30TR AHU
- ④ ELECTRICAL SWITCHBOARD.
- ⑤ RETURN AIR DUCT RISER 1
- ⑥ SUPPLY AIR DUCT RISER
- ⑦ RETURN AIR DUCT RISER 2



REV. NO.	DATE	DESCRIPTION
JOB :-		CLASS 10000 CLEAN ROOM
		AT R&D CENTRE TRIVANDRUM
CLIENT:-		HILL LIFECARE TRIVANDRUM
CONSULTANT:-		Alliance Consulting Engineers
		1/2, Akkarakoppadam, Vailkom, PIN 686 143
		Tel: +91 94470 37512 / +91 9485 99 7512
		Fax: 04829 222836, Email: oeev@alliance.com
DWG No:-		ACE/1116/118
		SHEET 1 OF 2