

**Further clarification to the Minutes of Pre- bid meeting held on 20.01.2016 for the work  
Construction of Urban Health Centre, Kurusikuppam, JIPMER, Puducherry**

**Tender reference no: HLL/ID/JIPMER/UHC – 02/15/36Dtd:08.01.2016**

Sl.No.	Queries of the Bidders	Reply by HLL
11.	What is the minimum cement content for M25 grade concrete which was not mentioned whereas M30 it was mentioned as 340kg/cum concrete.	The minimum cement content shall be 330 Kg / CuM. However, the successful bidder has to submit the design mix of M25 for HLL approval and Trial test will be carried out at HLL approved third party lab ( NABL accredited) to confirm the target strength.