

Amendment No: 6 Issued on dated 16/01/2015

Ref: Tender Enquiry No: HLL/PCD/IMPCL-12/14-15 dtd.04/09/2014 issued on 05/09/2014, subsequent Amendments with revised Tender Enquiry and 2nd Pre-Bid meeting held on 13/01/2015 at HLL Lifecare Ltd., B-14A, Sector-62, Noida - 201 307

The following amendments are issued with respect to the above tender Enquiry Document.

Section-VII- TECHNICAL SPECIFICATION

1. FOR:

4.4 MBBR (AERATION TANK)

4.4.1 Capacity 2kl

READ AS:

4.4 MBBR (AERATION TANK)

4.4.1 Capacity: **As per design requirement**

2. FOR:

4.5 SECONDARY TUBE SETTLER/ CLARIFIER

4.5.1 Capacity 3.5 kl

READ AS:

4.5 SECONDARY TUBE SETTLER/ CLARIFIER

4.5.1 Capacity: **As per design requirement**

3. NOTE:

Process Flow Chart of ETP cum STP

In the Process Flow Chart – Filter Press is not required & therefore deleted.

All other terms and conditions of this tender will remain unchanged.

.....**End**.....