

**MINUTES OF THE MEETING**

**PRE BID MEETING OF SUPPLY AND INSTALLATION OF GOODS LIFT\_PALLETS PP –  
WAREHOUSE EQUIPMENT AT PASTEUR INSTITUTE OF INDIA, COONOR**

**Document No.** : HBL/PIIC/LTE/GOODSLIFT\_PALLETS-  
PP\_WAREHOUSE\_EQP/001/16-17 dated 15.10.2016

**Venue** : HLL Biotech Limited, Chennai

**Date** : 24.10.2016

**Project** : Pasteur Institute of India, Coonor

**Attendees** : Enclosed As Annexure

**Issued by** : Mr. Suresh S (Sr. Manager –Procurement)

**Issued on** : 04.11.2016

**Issued from** : HLL Biotech Limited, Chennai

**MINUTES OF THE MEETING**

**PRE BID MEETING OF SUPPLY AND INSTALLATION OF GOODS LIFT\_PALLETS PP – WAREHOUSE EQUIPMENT AT PASTEUR INSTITUTE OF INDIA, COONOOR**

S.No.	Clarifications on queries									
A	<b>Discussion on Tender Enquiry Document: HBL/PIIC/LTE/GOODSLIFT_PALLETS-PP_WAREHOUSE_EQP/001/16-17 dated 15.10.2016</b>									
1.	<b>Page No: 2 of 20</b>									
	<table border="1"> <thead> <tr> <th>Sl</th> <th>Description</th> <th>Schedule</th> </tr> </thead> <tbody> <tr> <td>i.</td> <td>Closing date &amp; time for receipt of Tender</td> <td>07-NOV-2016, 15:30 Hrs</td> </tr> <tr> <td>ii.</td> <td>Time and date of opening of Technical Bids</td> <td>07-NOV-2016, 16:00 Hrs</td> </tr> </tbody> </table>	Sl	Description	Schedule	i.	Closing date & time for receipt of Tender	07-NOV-2016, 15:30 Hrs	ii.	Time and date of opening of Technical Bids	07-NOV-2016, 16:00 Hrs
	Sl	Description	Schedule							
	i.	Closing date & time for receipt of Tender	07-NOV-2016, 15:30 Hrs							
	ii.	Time and date of opening of Technical Bids	07-NOV-2016, 16:00 Hrs							
<b>Shall be read as</b>										
<table border="1"> <thead> <tr> <th>Sl</th> <th>Description</th> <th>Schedule</th> </tr> </thead> <tbody> <tr> <td>i.</td> <td>Closing date &amp; time for receipt of Tender</td> <td>17-NOV-2016, 15:30 Hrs</td> </tr> <tr> <td>ii.</td> <td>Time and date of opening of Technical Bids</td> <td>17-NOV-2016, 16:00 Hrs</td> </tr> </tbody> </table>	Sl	Description	Schedule	i.	Closing date & time for receipt of Tender	17-NOV-2016, 15:30 Hrs	ii.	Time and date of opening of Technical Bids	17-NOV-2016, 16:00 Hrs	
Sl	Description	Schedule								
i.	Closing date & time for receipt of Tender	17-NOV-2016, 15:30 Hrs								
ii.	Time and date of opening of Technical Bids	17-NOV-2016, 16:00 Hrs								

	Datasheet Point number and excerpt*/ description of the specification *	Point changed as / Comment
1.	S. No. 10. <b>Type of platform:</b> chequered	S.No.10. <b>Type of platform:</b> vendor to consider 6 mm MS plate clad with 1.5 mm SS chequered plate.
2.	S. No. 20: <b>Main body:</b> MS with suitable paint used for outdoor applications	S. No. 20: <b>Main body:</b> MS with FRP / PP coating on all the sides and on the roof. Corners / edges shall be properly clad to avoid water entry inside the lift area.
3.	S.No. 21: <b>Platform:</b> MS chequered plate	Point Deleted.
4.	S.No. 22. Electrical control panel shall be dual button control station with auto control type with UP & Down buttons. Electrical control panel shall be suitable for outdoor applications with IP protection.	S.No. 22. Electrical control panel shall be dual button control station with auto control level selector type with UP & Down buttons. Electrical control panel shall be suitable for outdoor applications with IP protection.
5.	S.No. 25. Interlocking details to be provided by vendor	S.No. 25. Vendor to consider electro mechanical latching system for interlocking.

**MINUTES OF THE MEETING**

**PRE BID MEETING OF SUPPLY AND INSTALLATION OF GOODS LIFT\_PALLETS PP –  
 WAREHOUSE EQUIPMENT AT PASTEUR INSTITUTE OF INDIA, COONOR**

6.	S.No. 38. Outside and inside cabin shall be fully covered from outside atmosphere and shall be suitable for outdoor application.	S.No. 38. Outside cabin shall be MS with FRP / PP coating on all the sides. Corners / edges shall be properly cladded to avoid water entry inside the lift. Inside cabin shall be fully covered with minimum 1.5 mm SS sheet on all the sides & roof.
7.	S.No. 39. Vendor has to consider dead plate matching at loading and unloading side to match with the platform as per the site conditions. Any other mechanical means required has to be considered by the vendor.	S.No. 39. Vendor to consider dimension of dead plate as Length: 2000 mm Width: 400 mm MOC: 6 mm MS plate cladded with 1.5 mm SS chequered plate.
8.		<b><u>S.No. 42 Additional point included:</u></b> <b><i>Vendor to consider clear opening width of the door of goods lift as 1.8 mtrs.</i></b>

For HLL Biotech Limited

  
 4/11/16.

Authorized Signatory



