

MINISTRY OF HEALTH & FAMILY WELFARE

(Govt. of India, Nirman Bhavan, New Delhi)

CORRIGENDUM-01Sub: **"Setting Up of Residential Complex at AIIMS Rishikesh (SH: External Development Works)"**Ref: Tender No. – **MoHFW /AIIMS-RISHIKESH/Ext Dev. /HLL/ID/2013**

Sl. No.	Ref to Tender	Bidder's queries	MoHFW/HLL Clarifications
1.	BOQ Item No. 22 & 23	In reference to the above tender your good self is requested to throw some light on item of waterproofing, Sir being a Non-DSR item, kindly specify the make/brand of the materials to be used, or the rates as you have taken of res / of Items from DSR-2013. Further Sir, to maintain a quality work, you need to have a qualitative products for which please mention, the company's name, since there is great difference of Rate in between locally available product & branded so is the position of Quality, henceforth it will not be fair competition, if rates are quoted on the so called local agency basis & branded material.	<p>Item is self-explanatory and make/brand of materials to be used is mentioned in the specifications given in the BOQ.</p> <p>Following materials of BASF/ Chemistik Brand or equivalent approved are to be used:-</p> <ol style="list-style-type: none"> 1. Non-shrinkage compensating grout of Flowcable 50 or equivalent 2. Two component based elastomeric, cementitious coating Master Seal 551 or equivalent 3. Liquid waterproofing admixture MasterPel 707 or equivalent <p>Work is to be got executed through a specialized agency. The Agency & Chemicals and Process shall be got approved from HLL Engineer-in-charge before execution as already provided in the Contract.</p>

Note: Corrigendum shall form part of tender document.

End of Corrigendum-01

