

Amendment No. 04

Date: 16/02/2016

Sub: Amendment to the Tender Enquiry Document

Ref: NIT No.: HLL/PCD/IMMU-09/15-16 dated 15.01.2016 and Amendment No. 03 dated 15-02-2016

The following changes have been incorporated in the referred NIT.

SECTION I NOTICE INVITING e-TENDERS (NIT)

The **Techno-Commercial Bids and Financial Bids** will only have to be **submitted online in the e-tendering portal of HLL (Physical Submission of Techno-Commercial Bids and Financial Bids is not required)**. The **Tender Fee and EMD** are to be **submitted physically at the time and venue** as per Tender Enquiry.

Section – VII Technical Specification

Schedule-1 Automatic Voltage Stabilizer (low Voltage) – 100V -280 V

The clause 1.1 is to be read as below:

- 1.1 Automatic regulation relay type voltage stabilizer will provide a preset AC Output 220V +/- 10 % for fluctuating AC input voltage.(i.e. 100-280 V)

Schedule-2 Automatic Voltage Stabilizer – 150V -280 V

Existing:

- 1.1 Automatic regulation relay type voltage stabilizer will provide a preset AC Output 220V +/- 10 % for fluctuating AC input voltage.(i.e. 100-280 V)

Read as:

- 1.1 *Automatic regulation relay type voltage stabilizer will provide a preset AC Output 220V +/- 10 % for fluctuating AC input voltage (i.e. 150-280 V)*

All other contents of the tender enquiry including terms & conditions remain unaltered.

Note: Prospective Bidders are also advised to check the website regularly prior to the closing date and time of online submission of bids