

Construction of Public Utility Medical Mart and Staff Wellness Centre including modern Swimming Pool at JIPMER, PUDUCHERRY

Pre Bid Queries- NAPC Ltd

S.No	Description	Query by M/s NAPC	Reply by HLL
CIVIL			
1	S.No: 23 & 24 (Expansion joint)	Kindly provide the drawing	Drawings to be furnished by the bidder based on the specification as mentioned in the BOQ for approval before ecevation.
2	S.No: 124 (Cement Concrete Pavement)	Kindly provide the thickness of pavement and Whether it is PCC or RCC.	Concrete Pavement shall be in Plain Cement Concrete with Minimum thickness 125mm
3	S.No: 126a (Bituminous sealant)	Kindly confirm the unit mentioned in BOQ	The unit shall be in Meters
ELECTRICAL AND SERVICES			
1	S.No: 86	No. of hydrant valve is 6 no. But given RRL hose quantity is 2 No.. Kindly confirm the quantity.	Quantity as per BOQ
2	S.No: 87	No. of hydrant valve is 6 no. But given Nozzle quantity is 2 No.. Kindly confirm the quantity.	Quantity as per BOQ
3	S.No: 69 & 70	Kindly confirm the pump capacity because as per norms minimum pump capacity 900lpm required for hydrant system	The pump is meant only for Domestic purpose
4	Fire fighting drawing	Kindly provide the following	
		a) Schematic layout	The schematic layout shall be furnished by the bidder as per NBC Norms.
		b) Fire tank capacity & location to layout	The fire tank capacity and location shall be furnished by the bidder as per NBC Norms
GENERAL			
1	Cement	We request you to approve the Zuari Cement	Shall be as per list of approved makes as mentioned in Part III A Special Conditions of Contract