

**MINISTRY OF HEALTH & FAMILY WELFARE  
CORRIGENDUM-01**

**Tender No-MoHFW/AIIMS-RISHIKESH/BFFW/HLL/ID/2014**

**Sub: SETTING UP OF RESIDENTIAL COMPLEX AT AIIMS RISHIKESH (Balance Fire Fighting works)**

Sl. No.	Queries/Clarifications	Reply /Clarifications
1.	Can the EMD be submitted in the shapes of FDR in your favour having a minimum period of 180 days?	The terms & provisions given in the tender remain unchanged.
2.	The completion period has been mentioned as 3 months at page No. 4 Table -3, while it is 2 months on page 36. Please clarify.	The completion period is 3(three) Months.
3.	Is radiography of welded joints mandatory required as mentioned at page 4 of volume III, Technical specifications. If so, what about the already laid pipes?	The radiography of welded joints for already laid down pipes will not be in the scope of the contractor. Other the terms & provisions given in the tender remain unchanged.
4.	Who will be responsible for leakages during hydraulic test of the already laid pipes?	The contractor will not be responsible for any leakage in the already laid down pipes. Other the terms & provisions given in the tender remain unchanged.
5.	Refer to item 1.7 of BOQ, the pressure gauge shall be either 0-7Kg/sqcm or 0-14Kg/sqcm in place of 0-10 Kg/sqcm.	Pressure Gauge having minimum range of 0-10 kg/ sq. cm may be accepted.
6.	Refer list of approved makes, the Butt welded fittings shall not be UL Listed, as these are not available.	At Sr. no. 08 in the List of Approved makes of material is modified as " Butt welded fitting ( C class fittings) instead of " Butt welded fitting (UL Listed)"
7.	Please add Exflame and Omex makes in Branch pipe and hose reel also as these are approved for hydrant valves and fire hoses. By adding this all firefighting equipment can be of same make.	<ol style="list-style-type: none"> <li>1. Makes for Gunmetal Branch Pipe shall be as follows: Newage / Ushafire / Winco / Kailash /Exflame/Omex.</li> <li>2. Makes for Hose Reel Drum shall be as follows: Newage/ Minimax/ Exflame/Omex</li> </ol>
8.	Refer Note 1 of approved makes, page 26 Volume –III; please confirm that the make shall be approved by the Consultant / E-in-C out of the list of approved makes.	The bidder shall seek prior approval of the vendor amongst the list of approved make from the Engineer in Charge(EIC) .
9.	List of approved makes for fire alarm system is not mentioned.	The makes for Fire Alarm System are 1.Agni , 2. Safeway, 3. Notifier
10.	The IS Code for fire Extinguisher (C024.5Kg Item – 3.1a) is IS : 15683 instead of IS : 2878.	The IS code 15683 is for Fire Extinguishers
11.	The Getech make for firefighting accessories & for fire extinguisher is to be record for approve makes.	The terms & provisions given in the tender remain unchanged.

Note: The corrigendum shall be part of the tender document.

\*\*\*End of Corrigendum-01\*\*\*

