

Amendment No. 1**Date: 21/04/2017****Sub: Amendment to the Tender Enquiry Document.****Ref: Tender Enquiry No.: HLL/PCD/NIB-21/16-17 dated 25.03.2017.**

The following changes are being incorporated for the following items in the referred tender enquiry.

Item	e- Tender Ref. No. (Event No.)	Description	Qty. (Nos.)	EMD (In Rs)
1	3000001907	Supply and Installation of Walk-in-Cold Room {-20°C & +2°C to +8°C}	1	96,000

EXISTING:

Sl. No.	Description	Schedule
c	Closing date & time for submission of tender fee and EMD in physical form	25.04.2017, 12:30 PM (IST) Bidders have to submit Original Bank Instruments viz. DD/BC/BG of tender fee and EMD within the above mentioned date and time
d	Closing date & time for submission of online bids	25.04.2017, at 02:00 PM (IST)
e	Time, date of e-tender opening of online bids	25.04.2017, at 03:00 PM (IST)

IMPORTANT NOTE :-Tender fee (Rs. 3000) and EMD (As applicable) should be deposited in the Tender Box located at **HLL Lifecare Limited, Procurement and Consultancy Division, B-14 A, Sector-62, Noida-201307, Uttar Pradesh on or before **25.04.2017, 12:30 PM (IST)**. Submission beyond stipulated date & time would result in **REJECTION** of BID.**

If EMD is submitted in the form of BG, then the validity of the BG should be at least 165 days from the date of tender opening.

READ AS:

Sl. No.	Description	Schedule
c	Closing date & time for submission of tender fee and EMD in physical form	05.05.2017, 12:30 PM (IST) Bidders have to submit Original Bank Instruments viz. DD/BC/BG of tender fee and EMD within the above mentioned date and time
d	Closing date & time for submission of online bids	05.05.2017, at 02:00 PM (IST)
e	Time, date of e-tender opening of online bids	05.05.2017, at 03:00 PM (IST)

IMPORTANT NOTE :-Tender fee (Rs. 3000) and EMD (As applicable) should be deposited in the Tender Box located at **HLL Lifecare Limited, Procurement and Consultancy Division, B-14 A, Sector-62, Noida-201307, Uttar Pradesh** on or before **05.05.2017, 12:30 PM (IST)**. **Submission beyond stipulated date & time would result in REJECTION of BID.**

If EMD is submitted in the form of BG, then the validity of the BG should be at least 165 days from the date of tender opening.

Section – VII

Technical Specifications

Walk in Cold room & Walk-in-Freezer (with common wall)

1. **Existing Specification:**

Clause 2. Operational Requirements:

2.3: Refrigeration system must be provided with it respective separate:

- condensing unit,
 - evaporator unit,
 - refrigeration unit,
 - electronic controls including micro processing control
 - pipe work and
 - other necessary control instrumentation,
- to ensure proper operation of each respective refrigeration system.

Read as:

Clause 2. Operational Requirements:

2.3: Refrigeration system must be provided with it respective separate:

- condensing unit,
 - evaporator unit,
 - refrigeration unit,
 - electronic controls including **micro processing control/PLC control**
 - pipe work and
 - other necessary control instrumentation,
- to ensure proper operation of each respective refrigeration system.

2. **Existing Specification:**

Clause 3.7.Refrigeration System:

3.7.1: microprocessor control single refrigeration system

Read as:

Clause 3.7.Refrigeration System:

3.7.1: **microprocessor control/PLC control** single refrigeration system

3. Existing Specification:

Clause 5.0.Shelves:

5.5: The material of the shelves should be non corrosive 304 grade stainless steel to take load of at least 0.075kg/cm².

Read as:

Clause 5.0.Shelves:

5.5: The material of the shelves should be non corrosive 304 grade stainless steel to take **load of at least 0.0075kg/cm² (Each shelf will take a load of 27 Kg).**

All other contents of the tender enquiry including terms & conditions remain unaltered.

Note: Prospective Bidders are also advised to check the website regularly prior to the closing date and time of online submission of bids