

Indian Medicines Pharmaceutical Corporation Ltd.

CORRIGENDUM -02

Subject: Modernization, Upgradation & Expansion of existing Plant facilities at IMPCL, Mohan (Package –II- Electrical Substation, DG Sets and other Electrical works)
Tender No: HLL/IDN/IMPCL/2013/14/02

Sl.No.	Ref to Tender	Bidder's queries	MoHFW/HLL Clarifications
1	Corrigendum-01 , Annexure-B at page No. 10 SPECIFIC REQUIREMENTS a) Technical Particulars	With reference to the Corrigendum-01- Annexure-B, on page no. 10 , as per IS/IEC norms the degree of protection for indoor HT Panel should be IP 4X instead of IP 55.	The description under Corrigendum-01 , Annexure-B at page No. 10 SPECIFIC REQUIREMENTS a) Technical Particulars : "Degree of Protection : > IP55" is modified as follows" Degree of Protection - IP 4X(for HT Panel)"
1.1			

*****END OF CORRIGENDUM-02*****

