

Clarification**Date: 22/04/2016****Sub:** Clarification to the BOQ.

- Ref:** (i) TED: HLL/PCD/PMSSY/AIIMS-II/14-RT-01/15–16 dated 31.12.2015
(ii) Clarification dated 04.01.2016, 12.01.2016 & 18.01.2016.
(iii) Amendment No.02 dated 07.03.2016
(iv) Amendment No. 03 dated 18.03.2016

Section – VII
Technical Specifications

1. For:-

| BOQ FOR MGPS - AIIMS RISHIKESH | | |
|---------------------------------------|---|--------------------|
| SN. | Item Description | Quantity |
| 15 | Supply installation testing and commissioning of Medical gas hose assemblies Hoses shall be color coded throughout their length as specified in British standards. 150m for O2, Air & Vacuum 20m for Co2,AGSS, N2O | 100m/20m (Each) |

Read as:-

| BOQ FOR MGPS - AIIMS RISHIKESH | | |
|---------------------------------------|---|---------------------------|
| SN. | Item Description | Quantity |
| 15 | Supply installation testing and commissioning of Medical gas hose assemblies Hoses shall be color coded throughout their length as specified in British standards. 100m for O2, Air & Vacuum 20m for Co2,AGSS, N2O | 100m/20m (Each) |